

KAWARTHA PINE RIDGE DISTRICT SCHOOL BOARD

Tender

PUR18-018-ITT

Lydia Trull PS Elevator Replacement

ADDENDUM NO. 3

This addendum shall form an integral part of the Tender documents for the above noted Tender and shall be read in conjunction therewith. This addendum shall, however, take precedence over all requirements as it pertains to the particular and specific items noted below.

1. **Add:** Addendum No.3 Prepared by Barry Bryan Associates

END OF ADDENDUM NO. 3



**BARRY BRYAN
ASSOCIATES**

Architects
Engineers
Project Managers

Project No.: 18010
Date: February 27 2018
Project: Kawartha Pine Ridge District School Board
Lydia Trull Public School, Elevator Replacement
80 Avondale Drive
Courtice, Ontario

The following information supplements and/or supersedes the original bid documents.

This Addendum forms part of the contract documents and is to be read, interpreted, and coordinated with all other parts. The cost of all contained herein is to be included in the contract sum. The following revisions supersede the information contained in the original drawings and specifications issued for the above-named project to the extent referenced and shall become part thereof.

1.0 Appendix F - Drawings

1.1 Mechanical/Electrical Addendum:

1. See attached Mechanical/Electrical Addendum No. ME-1, from Durham Energy Specialist Limited.

END OF ADDENDUM NO. 3



250 Water Street,
Suite 201
Whitby, Ontario
Canada
L1N 0G5

Tele: **905-666-5252**
Toronto: **905-427-4495**
Fax: **905-666-5256**
Email: bba@bba-archeng.com
www.bba-archeng.com



Durham Energy Specialist Limited

106-209 Dundas Street East, Whitby, Ontario L1N 7H8 905-430-7151 Fax: 905-430-7154
Email: info@durhamenergy.com Web: www.durhamenergy.com

Addendum No. ME-1

Project Name: KPRDSB Lydia Trull PS **Date:** February 27, 2018
Description: Lift Replacement **From:** Luigi Conforti, P. Eng.
Address: 80 Avondale Drive, Courtice **DES Job No:** 18-111
Client Contact: John Moses, BBA

This addendum shall form an integral part of the TENDER.

Mechanical

No Mechanical Items.

Electrical

1.1 Fire Alarm Scope of Work

- .1 Fire alarm control panel is a Simplex 4100ES.
- .2 Provide conventional devices as noted. Allow for any components/upgrades required to suit elevator recall with conventional devices.

TD: S/r: JLC

Cc: John Moses Barry Bryan Associates jmoses@bba-archeng.com