

ADDENDUM 02

Project Massey Centre Child Care Renovation
1102 Broadview Avenue, Toronto

Date: 19 August, 2019

Total pages Including cover: 2

The following changes, additions, deletions and clarifications are hereby made an integral part of the documents, including the drawings and specifications for the above project.

Item	Description
2.01	<p>Question: The tender form asks for alternate price #2(card readers) but card readers are shown as part of the cash allowance. Please clarify.</p> <p>Response: Please include any associated costs (cutting/patching/repair, coordination, management, etc) related to the provision of card readers by cash allowance on this line of the tender form.</p>
2.02	<p>Question: Dwg A1.0 note SD-2 – remove chain link fence & gate, are posts to be replaced?</p> <p>Response: Yes, removal of existing posts/footings shall be included within demolition scope. New fence posts are required in the area noted and specified in Detail 9/A6.1.</p>
2.03	<p>Question: Please provide names of the base building contractors if any (BAS, Fire Alarm etc.)</p> <p>Response: <u>Fire Panels and Monitoring</u> Siemens BLDG Technologies Ltd. #905-799-9937 Fire Services Spvsr. Jasper Tan #647-201-4854, jasper.tan@siemens.com Technician, Jim Hewitt #416-319-0653 Monitoring Systems Contracts Contact; Judith Gimes, Judith.gimes@siemens.com</p> <p><u>Security Access Control</u> G4S Secure Solutions (Canada) Ltd. Pete Nickerson, Consultant/Project Manager, 416-270-4672, pete.nickerson@ca.g4s.com</p> <p><u>HVAC (You are not obligated to use this HVAC contractor.)</u> Rankin Group Caledon 905 488-4603 King 289-467-6084 P.O. Box 377, Bolton, ON, L7E 5T3 Glenn Rankin, grankin@aireservck.ca</p>
2.04	<p>Question: Drawing A5.0 – Cannot find “FRP” from the Materials Legend.</p> <p>Response: “FRP” denotes Fibreglass Reinforced Panel and corresponds to Specification section 09750 Hygienic Wall Panels.</p>

2.05	<p>Question: Drawing 11/A6.0 – Please provide specifications for Toy Sanitizer.</p> <p>Response: Toy Sanitizer 'TS' specification is listed on M1.1.</p>
2.06	<p>Question: Door 120 – Please clarify the door operator is existing to be reused as per the Door Schedule or new as per Electrical drawing 6/E2.2.</p> <p>Response: Door operator for Door 120 is to be reused.</p>

End of Addendum 02