



October 9, 2020

THE REGIONAL MUNICIPALITY OF YORK

ADDENDUM #6

T-20-122

FOR: Construction of a New Elevator and 2nd Floor AODA Washroom

LOCATION: 145 Harry Walker Parkway, Town of Newmarket, Ontario

CLOSING DATE: October 14, 2020, 1:00:00 P.M. (Eastern Time)

Bidders are requested to incorporate the changes/clarifications noted below to the above noted Bid Documents in your possession and be governed accordingly.

1. BIDDERS QUESTIONS (Q) AND REGION'S RESPONSES (A)

Q1. In page # A901, door schedule shows only D1 type with 2 quantity, but in the drawing 3/A901 has elevation of D1 and D2. Where does D2 belong to?

A1. D2 are not required for this project.

Q2. Please provide us the base building sprinkler contractor's info?

A2. Control Fire Systems Ltd. and D&L Fire Protection Limited have done sprinkler work at 145 Harry Walker in the past.

Q3. Addendum 1 added Scranton as an acceptable manufacturer, however Scranton is a solid plastic toilet partition. Specifications are for metal partitions. Please confirm that either plastic or metal are acceptable?

A3. Yes either is acceptable.

Q4. Toilet Partitions: Item 2.2.1.3 calls for stainless steel hardware, item 2.2.1.8 calls for standard chrome. Which is correct?

A4. Stainless steel.

Q5. Toilet Partitions: Item 2.2.1.8 calls for continuous brackets (no sightline hardware) however item 3.1.6 calls for stirrup brackets. Which is correct?

A5. No sightline Hardware.

- Q6.** Washroom Accessories: Please confirm that the paper towel dispenser is required, as the model specified is typically supplied by a janitorial company with a paper contract. We are unable to source this model to purchase without contract.
- A6.** The Region will supply the paper towel dispenser. The Contractor is responsible for installation.
- Q7.** Please advise us the specs for the Washroom (Automatic Door Operator and Push Buttons.) I wonder if we can provide Ditec by Assa Abloy Door Operator (HA-8)
- A7.** Proceed with universal washroom device fit out as per electrical drawings. Ensure the following are included or approved equal and compatible with the following:
- | | |
|------------------|---|
| Auto Door Opener | 7900 LE (AUTO OPERATOR) |
| Auto Operator | Privacy Feature per CX-WEC11 Universal Restroom Kit |
| Auto Operator | Emergency Call Station per CX-WEC11 Universal Restroom Kit" |

Bidders shall acknowledge receipt of all addenda to this RFT prior to submitting their Bid. Bids that do not contain evidence of receipt of all addenda will be deemed to be "incomplete" and will not be accepted in the Bidding Website.

This addendum shall remain attached to and form part of the Contract Documents.

Yours truly,



For:

Marie Kavanagh
Senior Purchasing Analyst
Procurement Office