

KAWARTHA PINE RIDGE DISTRICT SCHOOL BOARD

PUR21-068-ITT

Chemong Public School Science Lab & Prep Room Renovation

ADDENDUM NO. 2

This addendum shall form an integral part of the bid documents for the above noted Tender and shall be read in conjunction therewith. This addendum shall, however, take precedence over all requirements as it pertains to the particular and specific items noted below.

Part 1 – Answers to Questions

Question 1: Roller Window Shade Specs are not defined. Dwg A201 Proposed Note 27 States “Supply & Install new Shades and New Blinds at Lab to KPRDSB Standards”. Spec Section 12 24 13 Roller Window Blinds includes a rather broad range of specs, including multiple fabric types, manual and motor operation details etc. Please clarify the specific details of the blinds to be provided, fabric type, operation etc. as necessary for tendering. Thank you.

Answer 1: Please see attached addendum prepared by CVW Group Architects.

Question 2: Please confirm that the architectural woodwork subtrade has to be a member in good standing with AWMAC. This is not a requirement of other KPR projects.

Answer 2: Yes, architectural woodwork subtrade shall be a member in good standing of the Architectural Woodwork Institute or the Architectural Woodwork Manufacturers Association of Canada or the Woodwork Institute.

Part 2 – Additional Information

ADD: CMV Group Architects Addendum No. 2, prepared by CMV Group Architects. (1 page)

END OF ADDENDUM NO. 2



ADDENDUM

4 - 247 Spadina Avenue
Toronto, Ontario
M5T 3A8

☎ 416.506.1600
☎ 416.506.0956

www.cmvarch.com

DATE **May 26, 2021**
PROJECT **Chemong Public School
Science And Preparation Room Renovation**
TO **Kawartha Pine Ridge District School Board
1994 Fisher Drive
Peterborough, Ontario
K9J 7A1**

ADDENDUM No **2**
PROJECT No **21A105**
ATTENTION **Cheryl Schnurr**

-
- 01 This Addendum shall be attached to the form of the Specifications and shall form an integral part of the Contract Documents. The contents of this Addendum shall be brought to the attention of all concerned.
 - 02 Receipt of the Addenda shall be acknowledged in the Tender Form.
 - 03 All trades shall read the Addenda.
 - 04 This addendum consists of **1** pages and attachments as noted.

Roller Window Shades Specification Section 12 24 13

Part 2.1 Manufacturers

Provide Solarfactive shades as listed in specification section 12 24 13.

Part 2.2 Hardware

Shades are to be chain operated manual control as noted in specification section 2.2.

Part 2.7 Shade Fabric Types

Provide Solarfactive 'Solarblock 300' as per specification section 2.7.1.1. and 2.7.1.2.
Colour to be selected by architect from manufacturers full range.

Otto Miller

PER CMV ARCHITECTS

DISTRIBUTION file