

**ISSUED: June 8, 2021** 

# **REQUEST FOR TENDER RFT #B21-15**

# **HVAC Upgrades – 8 Schools**

## ADDENDUM NO. 1

The following additional instructions and amendments shall apply and govern the contract accordingly:

## Question 1:

Hi there – we found out about the bid today. If we attend the mandatory meetings tomorrow-can we still bid?

#### Answer:

Valid submissions will only be accepted for the locations that you attended the mandatory site meetings for.

## Question 2:

Archie Stouffer ES HVAC - On Drawing M-2 for this school it notes to refer to structural drawings for the outdoor condensing unit however no structural drawings in the bid package can these be shared?

### Answer:

The Archie Stouffer outdoor condensing unit structural drawings are included as part of this addendum.

# Question 3:

Three of the schools call for integration into the existing BAS system (page M-1) and five of the schools do not have this same note. Is the intent to have all eight schools on the existing BAS in their respective schools?

#### Answer:

The 5 schools that do not have a note for BAS integration do not have BAS systems.

## ADD:

The following addendums including updated drawings have been uploaded to the documents section of Bids&Tenders.

Archie Stouffer ES HVAC #AD	D-14121-01-June 8, 2021
-----------------------------	-------------------------

Revised Drawings MEP Addendum #1-June 8, 2021

Bobcaygeon PS HVAC #ADD-13221-01-June 8, 2021

Revised Drawings MEP Addendum #1-June 8, 2021

Grandview PS HVAC #ADD-13321-01-June 8, 2021

Revised Drawings MEP Addendum #1-June 8, 2021

Honey Harbour PS HVAC #

Upgrade

#ADD-13821-01-June 8, 2021

Revised Drawings MEP Addendum #1-June 8, 2021

KP Manson PS HVAC #ADD-13921-01-June 8, 2021

Revised Drawings MEP Addendum #1-June 8, 2021

King Albert PS Gym &

Library HVAC Upgrades

#ADD-13521-01-June 8, 2021

Revised Drawings MEP Addendum #1-June 8, 2021

Mariposa ES

Gym HVAC Upgrades

#ADD-13421-01-June 8, 2021


Revised Drawings MEP Addendum #1-June 8, 2021

Spruce Glen PS HVAC


#ADD-14321-01-June 8, 2021

Revised Drawings MEP Addendum #1-June 8, 2021

## **END OF ADDENDUM NO. 1**



**HVAC WALL MOUNT SUPPORT** STEENHOF Building Services Group 3 40 Peter Street S., 4 Orillia, ON. L3V 5A9 Drawing No: Revision: CHECKED BY: SCALE: DRAWN BY: DATE: T: 705-325-5400 F: 705-325-8400 SK-01 1/2" = 1'-0" www.steenhofbuilding.com GF GF May-21



#### **GENERAL NOTES:**

- 1. PERFORM ALL WORK IN ACCORDANCE WITH THE REQUIREMENTS OF THE ONTARIO BUILDING CODE, LATEST EDITION.
- 2. ALL WORK TO BE CARRIED OUT IN ACCORDANCE WITH THE REQUIREMENTS OF THE OCCUPATIONAL HEALTH AND SAFETY ACT OF
- 3. CONTRACTOR SHALL RELOCATE EXISTING UTILITIES TO FACILITATE CONSTRUCTION.
- 4. THE CONTRACTOR SHALL EXAMINE ALL DRAWINGS AND SPECIFICATIONS. CHECK ALL DIMENSIONS AND REPORT ANY DISCREPANCIES BEFORE PROCEEDING WITH THE WORK.
- 5. NO PROVISION HAS BEEN MADE IN THE DESIGN FOR CONDITIONS OCCURRING DURING CONSTRUCTION. THE CONTRACTOR IS TO PROVIDE ALL NECESSARY BRACING AND SHORING REQUIRED FOR STRESSES AND INSTABILITY OCCURRING DURING CONSTRUCTION. IT SHALL ALSO BE THE RESPONSIBILITY OF THE CONTRACTOR TO PROVIDE ALL NECESSARY BRACING, SHORING, SHEET PILING OR OTHER TEMPORARY SUPPORTS TO SAFEGUARD ALL EXISTING OR ADJACENT STRUCTURES.
- 6. WHERE A GIVEN STANDARD IS REFERENCED, IT SHALL BE THE MOST CURRENT VERSION OF THE STANDARD THAT IS APPLICABLE.
- 7. ALL DESIGN LOADS NOTED ON STRUCTURAL DRAWINGS ARE WORKING LOADS UNLESS NOTED OTHERWISE.
- 8. DRAWINGS TO BE READ IN CONJUNCTION WITH NORTHSTAR ENGINEERING SEALED DRAWINGS M-2 FOR ARCHIE STOUFFER PUBLIC SCHOOL.

#### STRUCTURAL STEEL NOTES:

- 1. ALL STRUCTURAL STEEL SHALL BE NEW STOCK.
- 2. ALL STRUCTURAL STEEL SHALL BE FABRICATED AND ERECTED TO THE REQUIREMENTS OF CAN/CSA-S16.1.
- 3. ALL STRUCTURAL STEEL SHALL CONFORM TO THE REQUIREMENTS OF CAN/CSA-G40.20/G40.21, GRADE 350W. ALL STEEL PLATES SHALL CONFORM TO THE REQUIREMENTS OF CAN/CSA-G40.20/40.21, GRADE 300W.
- 4. ALL STRUCTURAL STEEL SHALL BE CLEANED, REPAIRED AND RECEIVE ONE SHOP COAT AND FIELD TOUCH UP OF APPROVED PRIMER PAINT, IN ACCORDANCE WITH THE REQUIREMENTS OF CAN/CSA-S16.1.
- 5. ALL WELDING SHALL BE CARRIED OUT IN ACCORDANCE WITH CAN/CSA W59 BY A FABRICATOR FULLY APPROVED UNDER CAN/CSA W47.1 DIVISION No.1 OR No.2.
- 6. ALL BOLTS, NUTS AND WASHERS FOR STRUCTURAL STEEL CONNECTIONS SHALL CONFORM TO ASTM A325M.
- 7. ALL ANCHOR BOLTS, NUTS AND WASHERS SHALL CONFORM TO ASTM A36 OR ASTM A307.
- 8. NO HOLES SHALL BE CUT IN STRUCTURAL STEEL WITHOUT THE PRIOR APPROVAL OF THE ENGINEER.
- 9. INSPECTION AND TESTING OF STRUCTURAL STEEL FRAMEWORK (SUCH AS, BUT NOT LIMITED TO, BOLT TORQUE, WELD QUALITY, ALIGNMENT) SHALL BE IN ACCORDANCE WITH CAN/CSA-S16.1 AND CSA W59 BY A QUALIFIED INSPECTION COMPANY.
- 10. SPLICES IN STEEL MEMBERS OTHER THAN THOSE SHOWN ON THE DRAWINGS SHALL NOT BE PERMITTED.
- 11. ALL WELDED JOINTS IN ARCHITECTURALLY EXPOSED STRUCTURAL STEEL SHALL BE GROUND SMOOTH AND SHALL HAVE ALL WELD SPLATTER REMOVED.
- 12. TOUCH UP SHOP PRIMER TO BOLTS, WELDS AND BURNED AND SCRATCHED SURFACES AT COMPLETION OF ERECTION.
- 13. SUBMIT SHOP DRAWINGS FOR ALL STRUCTURAL STEEL. CONNECTIONS ARE TO BE DESIGNED AND STAMPED BY A PROFESSIONAL ENGINEER IN ONTARIO.
- 14. ALL STEEL TO RECEIVE SP3 PREPARATION AND RECEIVED 2 SHOP COATS OF ZINC-RICH PRIMER. COLOUR TO BE DECIDED BY OWNER.



	Project:				Project No.:	
	ARCHIE STOUFFER PS				210207	
	Address: 12 VINTAGE CRESCENT, MINDEN, ONTARIO			REVISION SCHEDULE		
STEENHOF DULDING STRYCOS GROUP	Drawing Title:				1 -	
STEENHOF Building Services Group 40 Peter Street S., Orillia. ON. L3V 5A9	1107C 007CEE 10100111 3011 3111   4   -					
T: 705-325-5400 F: 705-325-8400 www.steenhofbuilding.com	DRAWN BY: GF	CHECKED BY: GF	DATE: May-21	SCALE: 1/2" = 1'-0"	Revision:	Drawing No: SK-03