



**DURHAM CATHOLIC
DISTRICT SCHOOL BOARD**
Learning and Living in Faith

T22-15 Exterior Opening Repairs at Multiple School Sites
ADDENDUM NO. 2

Issued by: Purchasing Services
Durham Catholic District School Board
652 Rossland Road West
Oshawa, Ontario L1J 8M7

This addendum will form a part of the bid documents for the above noted Bid and shall be read in conjunction herewith. This addendum will take precedence over all requirements of the original bid documents and any addenda issued previously.

Bidders shall acknowledge receipt of this addendum with their electronic bid submission on the declaration page in the bidding system

This Addendum forms part of the Tender Documents and amends the Tender Documents as described below.

1. **ARCHITECTURAL SPECIFICATIONS, PROJECT MANUAL VOLUME 1**

1.1 **DIVISION 01 - GENERAL REQUIREMENTS**

.1 **SECTION 01 10 00 - GENERAL INSTRUCTIONS**

.1 Add Clause 1.16.9 as follows:

“.9 Hazardous material removals / abatement must be scheduled for after hours and weekends.”

.2 **SECTION 01 35 43 - HAZARDOUS MATERIALS**

.1 Add Item 1.2 SCHEDULE as follows:

“1.2 SCHEDULE

.1 Hazardous material removals / abatement must be scheduled for after hours and weekends.”

2. **ARCHITECTURAL DRAWINGS**

2.1 **Monsignor Phillip Coffey HS A1 Key Floor Plan, Partial Floor Plans, Details & Notes**

.1 Delete Door 109A from scope of work outlined on Key Plan.

2.2 **Monsignor Phillip Coffey HS A2 Door Schedule, Details & Notes**

.1 Delete Door 109A from the Door and Frame Schedule.

.2 Frames F1 and F2 under Frame Types are to be 32mm wide instead of typical 50mm wide frames for Doors 102, 103, 104, 105, 106, and 108.

END OF ARCHITECTURAL ADDENDUM NO. 1