



Centre d'excellence en approvisionnement  
**FRANCOachat**

## **INVITATION TO TENDER**

*#23-18 École Secondaire Étienne-Brûlé - Electrical System and  
Transformer Replacement – CS Viamonde*

## **ADDENDUM #4**

**Issue Date: September 19, 2023**

**Submission Date: October 26, 2023**, at 2:00:00 p.m. (local time)

The Competitive procurement process Coordinator is:  
Kyle Patterson  
Centre d'excellence en approvisionnement FRANCOachat  
1, promenade Vanier, bureau 102  
Welland, ON L3B 1A1  
Email: [info@FRANCOachat.ca](mailto:info@FRANCOachat.ca)

#23-18 École Secondaire Étienne-Brûlé – Electrical System and Transformer Replacement – CS Viamonde  
**ADDENDUM #4**

DATE: October 18, 2023

This addendum will form part of the terms, conditions and specifications outlined in the Request for Tender – #23-18 École Secondaire Étienne-Brûlé – Electrical System and Transformer Replacement – CS Viamonde All other components of the RFT shall remain as provided.

---

**Section 1:**

***Please Refer to (ELECTRICAL ADDENDUM No. E02) included below.***

---

**.\*\*\*END OF ADDENDUM #4\*\*\***

**ELECTRICAL ADDENDUM No. E02**  
**October 18, 2023**

**Part 1            General – Generator Contractor Questions and Response**

- Q1:    Detail 02/E-21 - What is the double slash door shown in room 137?  
R1:    That is the existing chain linked fence inside Transformer space #137.
- Q2:    What is size of existing primary duct bank?  
R2:    Unknow.
- Q3:    Detail 01/E-01 - Please advise whether part of the existing primary duct bank is to be removed within the transformer room?  
R3:    Existing Primary duct bank inside transformer space shall be removed if interferes with new secondary duct bank.
- Q4:    Detail 01/E-01 – Please advise whether the existing concrete enclosed ducts are to be removed?  
R4:    Existing secondary busway shall be removed.
- Q5:    Please inform whether the existing transformer pad is precast or cast-Insite slab. We need dimension of this pad to estimate demolition price.  
R5:    Unknow.
- Q6:    Who is the fire alarm contactor?  
R6:    M-L Fire.
- Q7:    Please confirm that owner will pay to the fire alarm contactor for fire alarm verification.  
R7:    Contractor shall pay for verification.

END OF ADD-E02