



Addendum

Addendum – RFQ-CC-2025-01 Accessible Door Upgrades at Best and Bash Arena

Providing pictures and measurement of each door.

Question:

Can you please provide each door measurement and photos?

Answer:

Door A existing measurements: 43 inches wide by 84 inches tall (each)



Door B existing measurements: 43 inches wide by 84 inches tall (each).



Door C existing measurements: 47 inches wide by 84 inches tall (each).



Door D existing measurements: 34.75 inches wide by 84 inches tall.



Banquet Hall exterior door existing measurements: 36 inches wide by 84 inches tall (each).



Question:

Do all doors currently have operators/power supply? Can you provide photos of existing doors? Can you provide size and finish of the new hollow metal door?

Answer:

Only the banquet hall door has an operator/power supply. All other doors DO NOT. See addendum for photos of all existing doors. The new door required for Door D – Upper Level Seating (Home) will be 38 inches wide by 84 inches tall. As seen in the photo below, the frame is 54 ¾ inches wide and 107.5 inches tall. It will require sidelite and transom. The new hollow metal door will be primed finish. Town staff will paint after install.

