

---

Date: January 26, 2026,

Re: **ITT-17-26 Elevator Modernization - Queen Alexandra Community Centre**

---

Take notice that the City of Peterborough has issued addendum number 3 for Invitation to Tender # ITT-17-26 which is the third addendum issued to date.

You will be required to confirm you have downloaded and reviewed this addendum in bids&tenders™ prior to submitting your bid.

---

The following outlines amendments to the original documentation for the above noted Invitation to Tender.

#### **Item 1 – New Information**

Please take note the **B.7 Pricing Form – Schedule B** has been updated to include the additional work:

- Replace Ceiling with 1 HR Fire Rated Assembly - 2 Layer Type "X" Gypsum Wall Board Ceiling as per OBC SB-2 2.3.12.
- Patch and Repair Existing Exterior Foundation Wall where Damaged with Compatible Mortar Product
- Infill and Patch Hole in Masonry Wall between Washroom and Machine Room after Removal of Existing Exhaust Fan Ducting. Provide Material with Minimum 1 HR Fire Rating

#### **End of Addendum 3**