



Addendum #2

T26-12 - Washroom Renovations at Bellwood Public School

Closing Date: Tuesday, March 10, 2026 before 11:00 AM

Date Issued: March 5, 2026

Please review the following addendum and clarification. This document shall be considered a component of Request for Tender package **T26-12**. All other terms and conditions remain the same.

1) Bidders Questions:

Question 1:

please provide the contact information for the approved/base building roofing contractor

Answer 1:

Below is a list of approved roofing contractors:

Company Name	Location
Atlas-Apex Roofing	Etobicoke, ON
Bothwell-Accurate Co.	Mississauga, ON
Cordeiro Roofing Ltd.	Toronto, ON
Crawford Roofing	Toronto, ON
Dean Chandler Roofing	Scarborough, ON
Flynn Canada	Mississauga, ON
George Roque Roofing	Hamilton, ON
Nortex Roofing Ltd.	Toronto, ON
Roque Roofing	Hamilton, ON
Schreiber Brothers Roofing	Hamilton, ON
Semple Gooder Roofing	Toronto, ON
Solar Roofing & Sheet Metal	Toronto, ON

Trio Roofing Systems	Brampton, ON
Triumph Roofing & Sheet Metal Inc.	Brampton, ON

Question 2:

please provide the toilet partition specifications

Answer 2:

Please refer to section 2.4 Toilet Partitions of specification section 10 28 13 Washroom Accessories.

Question 3:

Due to our current workload and capacity, could we please request a two week extension on the closing date?

Answer 3:

No changes to the closing date.

Question 4:

1. Does 8" block needs to be lightweight ?

Answer 4:

Yes.

Question 5:

2. Is there any vertical rebar required for 6" block walls ?

Answer 5:

No.

Question 6:

Good morning,

What is the height from finished floor to the underside of steel deck?

Thank you

Answer 6:

At the 2nd floor, the height from the finished floor to the underside of steel deck is +3600mm as per original architectural drawings dated May 1987.

End of Addendum.