

**REQUEST FOR TENDER  
RFT 2025-052-AC ADDENDUM #1**

**Classroom Renovation DRA 105 & 114**

March 26, 2026

This Addenda shall become part of the Request for Tender (RFT) documents. The information contained in the addendum supersedes and amends the RFT documents and previous addenda, and Bidders are solely responsible to ensure they have received, and that their Tender incorporates, all addenda issued prior to RFT closing, and all costs resulting from such addenda.

**Question:** Are the door operators to be connected to the fire alarm system? This is typically required if the door is installed in a wall providing fire separation between zones.

**Answer:** *Yes, the door operators would need to be connected to the fire alarm system.*

**Question:** Is this connection is required, do we need to provide CAN/ULC-S1001 Integrated Systems Testing?

**Answer:** *Yes, CAN/ULC-S1001 Integrated Systems Testing is required.*

**Question:** Could you please provide the specifications for the replacement lights?

**Answer:** *Replace all existing lights with Sona Model: #77-1-1-L-A-C-AG-08-7-D-S-W. New lights are to be of same model. See attached specification sheet for refence.*

**Question:** Please confirm if the wall intersects with the existing wood ceiling. If it does, please provide specifications for the ceiling and details on how to patch and repair the wood ceiling. Please provide the contact information for the supplier/installer if available.

**Answer:** *The expectation is that that walls do not intersect with the existing wood ceiling but instead is beneath the existing wood ceiling. The wood ceiling was already existing prior to the recessed entryway being installed.*

**Question:** Please provide the contact information for the base building fire alarm contractor.

**Answer:** *Fire system service contractor: Herbert Williams # 1-866-292-8630*

**Question:** Please provide Communications/Data specifications such as the cabling type, racking requirements, backbone requirements, and patching.

**Answer:** *Use vendor - Your Office Communication P.O. BOX 123, Warkworth, ON K0K 3K0  
Email: yocsolutions@gmail.com Telephone: (705) 872-2097*