

INSTITUTION: University of Ontario Institute of Technology
("Ontario Tech University")
TITLE: Shawenjigewining Hall Interior Renovations
NO.: RFPOT04072026
ADDENDUM NAME: Questions and Responses
ADDENDUM NO.: 3

This Addendum forms part of the Request for Proposal documents and shall be read in conjunction with the original RFP and any previously issued addenda. All other terms and conditions remain unchanged.

- 1) There is discrepancy between room finishes schedule and floor finishes plan in drawing A203 in phase 3. (see Office, Faculty room)

RESPONSE: FF4 is the correct floor finish for Room 470 Office, Faculty. Room Finish Schedule will be corrected at IFC.