



SIMCOE MUSKOKA CATHOLIC
DISTRICT SCHOOL BOARD

ADDENDUM #1
Bid Opportunity: T-26-32 - Flooring and Millwork
Replacement - HFA
Closing Date: May 12, 2026, at 2:00 PM local time

This Addendum shall take precedence over all requirements of the previously issued specifications and plans in the Call for Bid document(s) with which it may prove to be at variance with, unless otherwise clarified by the Board.

The following document(s) and verbiage shall form part and parcel of the Call for Bid document(s):

Question 1:

Please confirm if sink drains are to match existing upon reinstallation or if can be updated?

Answer 1:

Sink drains to be updated to system 15 PVC piping.

Question 2:

Please confirm that all classrooms and rooms that are receiving new millwork, etc. are to also receive new flooring. The drawing indicates only certain rooms to remove and replace existing flooring.

Answer 2:

All the rooms in the areas of work are to get new flooring. Rooms not receiving new millwork are Library #144, Librarian Office #144C, Guidance #145, Guidance Office #145A, & Kitchen in room #143, please refer to the drawings.

End of document.