

Prepared By:
Bob Mason
7000 Kinsmen Court
Niagara Falls, ON L2H 0Y5
bmason@graybarcanada.com
D:905-374-1113

Proposal Name: DURHAM COLLEGE

Quote Name: DURHAM COLLEGE

Proposal Number: P-260407-5976006

Quote Number: Q-6879798

Quote Date: 04/21/2026

Through Addenda Number: 0

Sales Representative: ROBERT ALLEN

Conditions of Sale

The quotation and accompanying Bill of Material and Quote Addendum are to be considered as one entity. This quotation is subject to Schneider Electric CANADA, Inc.'s published terms and conditions.

This quotation is per our interpretation only of information available at time of quotation. It is the responsibility of the purchaser to confirm this bill of material. Changes to this bill of material could result in a price increase. Unless noted otherwise, lamicoid nameplates, fuses, entry plates, co-ordination study and pre-service testing are not included in this quotation.

All equipment to be finished standard ASA gray.

Shipment estimates do not include transit time. Transportation times vary depending on plant location, shipping method, site destination, weather conditions and or border clearance times. If required, please work with your Schneider Electric Project Manager to determine estimated transit time.

Prices quoted are in Canadian dollars (CAD) and are valid for a period of 60 days from date of quotation. Any Goods and/or Services ordered must be scheduled for completion within 365 days of SE's express acceptance of the PO, or such other completion date as expressly agreed by a duly authorized SE representative in writing ("Completion Date"). Any extension by Purchaser of the Completion Date will give the right to SE in its sole discretion to adjust the price for products and/or services, to the extent that such change is not directly and exclusively caused by SE. Seller shall have in addition the right to change the price for products and/or services that are not unconditionally released to manufacture or approved for performance within ninety (90) days from receipt of purchase order or from approval drawing submittal to the Purchaser for approval, whichever date is later. All quotations are based on standard SE packaging.

Pricing

Total AUTHORIZED CA Dollars

Seq #	Qty	Product Description	Price Each	Subtotal
1	1	Designation : PANEL P-2W Product Details : 1 - NQ NL ML Panel (INTERIOR)-NQ Non-Linear Panelboard Consisting of 208Y/120V 3Ph 4W 60Hz SCCR: 22kA Fully Rated Main Lug Only: 250A Branch Neutral Lug Material: Aluminum incoming conductors per NEC, CEC, NOM: Phase Lugs: 1 - 1/0 - 750, (2) 1/0 - 350 kcmil Neutral Lugs: Two (2) 1/0-300 kcmil Bus: 400A Rated Copper: Silver/Tin Plated CU Ground Bar 42 Circuit Interior Type 1,Box: 50H x 20W x 5.75D Incoming: Bottom Trim: Surface with Door Box Cat No: MH50 Front Cat No: NC50VS Ref. Drawing: PBA709A Feeders: 1 - 60A/3P QOB-VH 2 - 20A/3P QOB-VH 26 - 30A/1P QOB-VH 4 - 15A/1P QOB-VH Prepared Space 1 - 15A/3P QOB-VH Optional Features: Standard Panel (Box Ahead),200% Neutral,Additional Copper Ground Bar,Copper Ground Bar 1 - MH50-PANELBOARD ENCLOSURE/BOX TYPE 1 50H 20W 1 - NC50VS-PANELBOARD COVER/TRIM NF TYPE 1 VS 50H		

Seq #	Qty	Product Description	Price Each	Subtotal
2	1	Designation : PANEL DP-6W Product Details : 1 - ILINE NL ML PNLB (INT BOX TRIM)-I-Line Non-Linear Rated Consisting of 600Y/347V 3Ph 4W 60Hz SCCR: 50kA Fully Rated Main Lug Only: 400A Branch Neutral Lug Material: Aluminum Incoming conductors per NEC, CEC, NOM: Phase Lugs: 1 - (2) #4 - 600 kcmil Neutral Lugs: (4)250 kcmil Cu or (4)350 kcmil Al Bus: 600A Rated Copper: Tin Plated CU Ground Bar 72" of Mounting Inches Type 1,Box: 91H x 32W x 9.5D Incoming: Bottom Trim: Four-Piece Surface Box Cat No: HC3291DB9 Front Cat No: HCM91TSV Ref. Drawing: PBA470 Type: HCJ Feeders: 7 - 15A/3P HL 2 - 20A/3P HL 1 - 35A/3P HL 1 - 100A/3P HL 1 - 90A/3P HL Optional Features: Ship Completely Assembled,200% Neutral,Additional Copper Ground Bar,Copper Ground Bar		

Seq #	Qty	Product Description	Price Each	Subtotal
3	1	Designation : P2-P Product Details : 1 - NQ442L2C-PNLBD INT NQ 225A MLO 42 CKT 3P CU Consisting of 208Y/120V 3Ph 4W 60Hz SCCR: 22kA		

Fully Rated

Main Lug Only: 60A

Branch Neutral Lug Material: Aluminum

Incoming conductors per NEC, CEC, NOM:

Phase Lugs: 1 - #6 - 2/0 AWG

Neutral Lugs: Two (1) #6-300 kcmil

AL Ground Bar

Bus: 225A Rated Copper: Silver/Tin Plated

42 Circuit Interior

Type 1, Box: 38H x 20W x 5.75D

Incoming: Bottom Trim: Surface with Door

Box Cat No: MH38 Front Cat No: NC38S

Ref. Drawing: PBA701A

Feeders:

2 - 20A/3P QOB-VH

2 - 15A/3P QOB-VH

1 - 15A/2P QOB-VH

3 - 20A/1P QOB-VH

13 - 15A/1P QOB-VH

12 - 15A/1P QOB-VH Prepared Space

Optional Features:

Standard Panel (Box Ahead), 200%

Neutral, Standard Ground Bar

1 - NQNL2-PNLBD NQ 225A 200% NEUTRAL KIT

1 - PK27GTA-LOAD CENTER EQUIPMENT GROUND BAR ASSY

2 - QOB320VH-MINIATURE CIRCUIT BREAKER 240V 20A

2 - QOB315VH-MINIATURE CIRCUIT BREAKER 240V 15A

1 - QOB215VH-MINIATURE CIRCUIT BREAKER 240V 15A

3 - QOB120VH-MINIATURE CIRCUIT BREAKER 120/240V 20A

13 - QOB115VH-MINIATURE CIRCUIT BREAKER 120/240V 15A

1 - MH38-PANELBOARD ENCLOSURE/BOX TYPE 1 38H 20W

1 - NC38S-PANELBOARD COVER/TRIM NF TYPE 1 S 38H

REV	DESCRIPTION	BY	DATE	---	----	---	---/---/---
-	-----	--	---/---/---	-	-----	--	---/---/---

CKT NO	ACCESSORIES	TYPE	RATING AMP/P		RATING AMP/P	TYPE	ACCESSORIES	CKT NO
1								2
3		QOB-VH	60/3		20/3	QOB-VH		4
5								6
7								8
9		QOB-VH	20/3		15/3	QOB-VH		10
11								12
13		QOB-VH	30/1		30/1	QOB-VH		14
15		QOB-VH	30/1		30/1	QOB-VH		16
17		QOB-VH	30/1		30/1	QOB-VH		18
19		QOB-VH	30/1		30/1	QOB-VH		20
21		QOB-VH	30/1		30/1	QOB-VH		22
23		QOB-VH	30/1		30/1	QOB-VH		24
25		QOB-VH	30/1		30/1	QOB-VH		26
27		QOB-VH	30/1		30/1	QOB-VH		28
29		QOB-VH	30/1		30/1	QOB-VH		30
31		QOB-VH	30/1		30/1	QOB-VH		32
33		QOB-VH	30/1		30/1	QOB-VH		34
35		QOB-VH	30/1		30/1	QOB-VH		36
37		QOB-VH	30/1		30/1	QOB-VH		38
39	PREPARED SPACE	QOB-VH	15/1		15/1	QOB-VH	PREPARED SPACE	40
41	PREPARED SPACE	QOB-VH	15/1		15/1	QOB-VH	PREPARED SPACE	42



PHYSICAL DATA

ENCLOSURE Type 1
 Surface with Door
 FRONT CAT#: NC50VS
 BOX CAT#: MH50

DIMENSIONS:
 50"(1270mm)Hx20"(508mm)Wx5.75"(146mm)D
 PBA: 709A
 Branch Neutral Lug Material: Aluminum
 BUSSING: 400A RATED COPPER BUS
 Silver/Tin Plated

OPTIONAL FEATURES:
 Copper GROUND BAR
 200% SOLID NEUTRAL
 ADDITIONAL Copper GRD BAR

ELECTRICAL DATA

SYSTEM: 208Y/120V 3Ph 4W 60Hz
 System Ampacity: 250A
 22kA SYMS. SCCR
 Fully Rated


MAIN: MAIN LUGS : 250A
 Bottom FEED
 INCOMING CONDUCTORS(S) PER NEC, CEC, NOM:
 Wire Bending Space:
 Phase Lugs: 1 - 1/0 - 750, (2) 1/0 - 350 kcmil
 Neutral Lugs: 2- ((1) 1/0-750 KCMIL or
 (2) 1/0-300 KCMIL)

-----BRANCH SUMMATION-----
 1 - 60A/3P QOB-VH 2 - 20A/3P QOB-VH
 26 - 30A/1P QOB-VH 4 - 15A/1P-PS QOB-VH
 1 - 15A/3P QOB-VH

JOB NAME: DURHAM COLLEGE	EQUIPMENT DESIGNATION: PANEL P-2W
JOB LOCATION:	EQUIPMENT TYPE: NQ (Circuit Breaker Type) PANEL 1 OF 1
DRAWN BY: CAD	DRAWING TYPE: ONE LINE DIAGRAM
ENGR:	SQUARE D by Schneider Electric
DATE: April 07 2026	
DRAWING STATUS: QUOTE	DWG# 00-6879798-214130294-01 PG 1 OF 1 REV -

REV	DESCRIPTION	BY	DATE	---	----	---	---/---/---
-	----	---	---/---/---	-	----	---	---/---/---

CKT NO	ACCESSORIES	TYPE	RATING AMP/P	PHASE BUS CONN	PHASE BUS CONN	RATING AMP/P	TYPE	ACCESSORIES	CKT NO
	4.50" BLANK							4.50" BLANK	
	4.50" BLANK							4.50" BLANK	
1		HL	15/3	A B C		15/3	HL		2
3		HL	15/3	A B C		15/3	HL		4
5		HL	15/3	A B C		15/3	HL		6
7		HL	20/3	A B C		15/3	HL		8
9		HL	35/3	A B C		20/3	HL		10
11		HL	100/3	A B C		90/3	HL		12



PHYSICAL DATA

ENCLOSURE Type 1
 Four-Piece Surface
 FRONT CAT#: HCM91TSV
 BOX CAT#: HC3291DB9

DIMENSIONS:
 91"(2311mm)Hx32"(813mm)Wx9.5"(241mm)D
 PBA: 470

Branch Neutral Lug Material: Aluminum

BUSSING: 600A RATED COPPER BUS
 Tin Plated

OPTIONAL FEATURES:
 SHIP COMPLETELY ASSEMBLED
 Copper GROUND BAR
 200% SOLID NEUTRAL
 ADDITIONAL Copper GRD BAR

ELECTRICAL DATA

SYSTEM: 600Y/347V 3Ph 4W 60Hz
 System Ampacity: 400A
 50kA SYMS. SCCR
 Fully Rated

MAIN: MAIN LUGS : 400A
 Bottom FEED
 INCOMING CONDUCTORS(S) PER NEC, CEC, NOM:
 Wire Bending Space:
 Phase Lugs: 1 - (2) #4 - 600 kcmil
 (4)250 kcmil Cu or
 (4)350 kcmil Al
 PBA: 470

-----BRANCH SUMMATION-----

7 - 15A/3P HL	2 - 20A/3P HL
1 - 35A/3P HL	1 - 100A/3P HL
1 - 90A/3P HL	

JOB NAME: DURHAM COLLEGE	EQUIPMENT DESIGNATION: PANEL DP-6W
JOB LOCATION:	EQUIPMENT TYPE: I-Line (Circuit Breaker Type) PANEL 1 OF 1
DRAWN BY: CAD	DRAWING TYPE: ONE LINE DIAGRAM
ENGR:	SQUARE D by Schneider Electric
DATE: April 07 2026	
DRAWING STATUS: QUOTE	DWG# OQ-6879798-214132563-01 PG 1 OF 1 REV -

REV	DESCRIPTION	BY	DATE	--	----	--	---/---/---
--	----	--	---/---/---	--	----	--	---/---/---

CKT NO	ACCESSORIES	TYPE	RATING AMP/P		RATING AMP/P	TYPE	ACCESSORIES	CKT NO
1								2
3		QOB-VH	20/3		20/3	QOB-VH		4
5								6
7								8
9		QOB-VH	15/3		15/3	QOB-VH		10
11								12
13					20/1	QOB-VH		14
15		QOB-VH	15/2		20/1	QOB-VH		16
17		QOB-VH	20/1		15/1	QOB-VH		18
19		QOB-VH	15/1		15/1	QOB-VH		20
21		QOB-VH	15/1		15/1	QOB-VH		22
23		QOB-VH	15/1		15/1	QOB-VH		24
25		QOB-VH	15/1		15/1	QOB-VH		26
27		QOB-VH	15/1		15/1	QOB-VH		28
29		QOB-VH	15/1		15/1	QOB-VH		30
31	PREPARED SPACE	QOB-VH	15/1		15/1	QOB-VH	PREPARED SPACE	32
33	PREPARED SPACE	QOB-VH	15/1		15/1	QOB-VH	PREPARED SPACE	34
35	PREPARED SPACE	QOB-VH	15/1		15/1	QOB-VH	PREPARED SPACE	36
37	PREPARED SPACE	QOB-VH	15/1		15/1	QOB-VH	PREPARED SPACE	38
39	PREPARED SPACE	QOB-VH	15/1		15/1	QOB-VH	PREPARED SPACE	40
41	PREPARED SPACE	QOB-VH	15/1		15/1	QOB-VH	PREPARED SPACE	42



PHYSICAL DATA

ENCLOSURE Type 1

Surface with Door
 FRONT CAT#: NC38S
 BOX CAT#: MH38

DIMENSIONS:

38"(965mm)Hx20"(508mm)Wx5.75"(146mm)D

PBA: 701A

Branch Neutral Lug Material: Aluminum

BUSSING: 225A RATED COPPER BUS
 Silver/Tin Plated

OPTIONAL FEATURES:

200% SOLID NEUTRAL
 ALUMINUM GROUND BAR

ELECTRICAL DATA

SYSTEM: 208Y/120V 3Ph 4W 60Hz

System Ampacity: 60A
 22kA SYMS. SCCR
 Fully Rated

MAIN: MAIN LUGS : 60A

Bottom FEED

INCOMING CONDUCTORS(S) PER NEC, CEC, NOM:

Wire Bending Space:

Phase Lugs:1 - #6 - 2/0 AWG

Neutral Lugs: Two (1) #6-2/0 AWG

-----BRANCH SUMMATION-----

2 - 20A/3P QOB-VH	2 - 15A/3P QOB-VH
1 - 15A/2P QOB-VH	3 - 20A/1P QOB-VH
13 - 15A/1P QOB-VH	12 - 15A/1P-PS QOB-VH

JOB NAME: DURHAM COLLEGE	EQUIPMENT DESIGNATION: P2-P
JOB LOCATION:	EQUIPMENT TYPE: NQ (Circuit Breaker Type) PANEL 1 OF 1
DRAWN BY: CAD	DRAWING TYPE: ONE LINE DIAGRAM
ENGR:	SQUARE D By Schneider Electric
DATE: April 21 2026	
DRAWING STATUS: QUOTE	DWG# OQ-6879798-215679430-01 PG 1 OF 1 REV -